

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 163/PLA/25

Dated: 24.02.2025

It is certified that an inspection team headed by Md. Sahid....Pradhan.....

(Name of Officers with designation) from Patharghata Gram Panchayat.....

(Name of Department/ Office) inspected the ..Woodridge International School.....

(Name & Address of the school) on ..23.02.2025.....(date of inspection) and found that the ..Woodridge International School.....(Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of ..22.02.2030 (05 years) ..

Pradhan

Patharghata Gram Panchayat
Venchijote, New Chamta, Darjeeling

Signature with Seal: ..

Name : Md. Sahid.....

Designation : Pradhan, Patharghata G.P.....

Name & Address of the Office / Department : Patharghata G.P.
Venchijote New Chamta, Darjeeling

To

Woodridge International School
Rajpura

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Drai

Principal
Woodridge International School
Patharghata - 734009

Manager
Woodridge International School
Patharghata
P.O. New Chamta, Pin-734009



GOVERNMENT OF WEST BENGAL,
DIRECTORATE OF PUBLIC HEALTH ENGINEERING,
OFFICE OF THE EXECUTIVE ENGINEER,
SILIGURI WATER SUPPLY DIVISION,
DISTRICT LABORATORY AT FULBARI,
SILIGURI

PHYSICAL AND CHEMICAL TEST REPORTS:

Date Of Collection	12.03.2025
Date Of Analysis	12.03.2025
Date Of Reporting	13.03.2025

SL NO.	Parameters	Acceptable Limit (as per IS 10500 : 2012)	Cause of Rejection	RESULT	
				Place	Wood Ridge International School, New Chumta
				Source	Filter Water
				Sender	Wood Ridge International School
1.	Turbidity (NTU)	1	5		0.64
2.	pH	6.5 to 8.5	No Relaxation		6.91
3.	TDS(ppm)	500	2000		8
4.	Iron (mg/l)	1.0	No Relaxation		0.05
5.	Res. Chlorine (mg/l)	0.2	1.0		0
6.	Fluoride (mg/l)	1.0	1.5		0.16
7.	Total Hardness(mg/l)	200	600		8
8.	Total Alkalinity(mg/l)	200	600		9

*The tests done with the Sample as deposited by the Party.

Physical & Chemical Test Charge Rs. 900.00/-

Received Vide GRN No. 192024250434407588

Dated: 07/03/2025


Chemist/Bacteriologist,
Darjeeling District Laboratory,
Fulbari, W.T.P.



Junior Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.

Memo No. 773/SWSD /SD: Dated, Siliguri, the 17 03 2025

Copy forwarded for information and necessary action to:-

1. Wood Ridge International School.
2. Office Copy.

Report No: Chem/2025/Mar-14


Assistant Engineer-II,
Siliguri Water Supply Division,
P.H. Engineering Dte.


Manager
Woodridge International School
Patharghatta
P.O. New Chamta, Pin-734009


Principal
Woodridge International School
Patharghatta - 734009



GOVERNMENT OF WEST BENGAL,
DIRECTORATE OF PUBLIC HEALTH ENGINEERING,
OFFICE OF THE EXECUTIVE ENGINEER,
SILIGURI WATER SUPPLY DIVISION,
DISTRICT LABORATORY AT FULBARI,
SILIGURI

BACTERIOLOGICAL ANALYSIS:

Date Of Collection	12.03.2025
Time Of Collection	01.00 PM
Date Of Analysis	12.03.2025 TO 13.03.2025
Date Of Reporting	13.03.2025

Sl No.	Bacteriological Parameters	Acceptable Limit	RESULT	
			Place	Wood Ridge International School, New Chumta
			Source	Filter Water
			Sender	Wood Ridge International School
1.	Total Coliform Present/Absent (CFU/100 ML)	Absent	ABSENT	
2.	Faecal Coliform Present/Absent (CFU/100 ML)	Absent	ABSENT	
3.	WATER BACTERIOLOGICALLY SAFE/UNSAFE	--	SAFE	


*The tests done with the Sample as deposited by the Party.

Bacteriological Test Charge Rs. 500.00/-

Received Vide GRN No. 192024250434407588

Dated: 06/03/2025


Chemist/Bacteriologist,
Darjeeling District Laboratory,
Fulbari, W.T.P.


Junior Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.


Memo No. 774/SWSD/SD:


Dated, Siliguri, the 17 03 2025

Copy forwarded for information and necessary action to:-

1. Wood Ridge International School.
2. Office Copy.

Report No: Bact/2025/Mar-13


Assistant Engineer-II,
Siliguri Water Supply Division
P.H. Engineering Dte.


Manager
Woodridge International School
Patharghatta
P.O. New Chamta, Pin-734009


Principal
Woodridge International School
Patharghatta - 734009